# **IO14A, IO14B**

## Combined Module with 3AI + 1 AO + 8 DI + 2 DO

### Data Sheet

Doc: 40421 v1.06









### **INTRODUCTION TO LB2 I/O SERIES**

Before using the LB2 Series I/O Modules, read the LB2 User manual.

The Brodersen LB2 modules can be used with the RTU32N and RTU32M series products. The I/O modules are in two parts, a bottom part containing the backplane bus, and a top part containing the I/O board and logic. All LB2 I/O modules are hot pluggable and equipped with a 200 MHz processor to handle filtering, de-bouncing and logic processing of I/O.

Module firmware updates are managed by the RTU using Brodersen Worksuite. Use only genuine Brodersen bus cables for connection to Brodersen RTUs and extension of I/O module blocks. The LB2 connection cables are made to handle the power and shielding requirements of the LB2 bus communications. The maximum overall length of complete system is 30m. Each I/O module & Power supply module is calculated as 2cm. The cables are as their length indicates, e.g. UCC-610/100 cable is 100 cm.

The maximum number of I/O modules on one LB2 Bus is 60.

### Cable ordering codes:

UCC-610/25	25cm LB2 Cable
UCC-610/50	50cm LB2 Cable
UCC-610/100	100cm LB2 Cable
UCC-610/200	200cm LB2 Cable

### POWER SUPPLY MODULE BACKPLANE PART

Description	Part Nr.
BUS module for IOs, Start	BB21A
BUS module for IOs, Middle	BB21B
BUS module for IOs, Extension	BB21C


### **VERSIONS / ORDERING CODES**

Hardware basic version	
Order code: IO14A	Current input Al
Order code: IO14B	Voltage input Al

### I/O INTERFACE

This module provides 3x analog input channels (IO14A has current inputs, IO14B has voltage inputs), 1x analog output channel (current), 8x digital input channels (10-30VDC – includes 2x 5kHz counters) and 2x relay output channels. Counters can also be DI.

2x 12 way 3.5mm pluggable spring clamp connectors. The maximum conductor cross sectional area is AWG 16 (1.3mm<sup>2</sup>). The wire conductor type should be Copper and it must meet the minimum temperature criteria of 105°C.



**TERMINAL LAYOUT** 

### **Connector top section A:**

Pin 1:	DO0 N.O.
Pin 2:	DO0 Common
Pin 3:	DO0 N.C.
Pin 4:	DO1 N.O.
Pin 5:	DO1 Common
Pin 6:	DO1 N.C.
Pin 7:	AI0 +
Pin 8:	AI0 –
Pin 9:	AI1 +
Pin 10:	AI1 –
Pin 11:	AI2 +
Pin 12:	AI2 -

Document no. 40421 106 IO14A & IO14B



### IO14A & IO14B Data Sheet

Connector bottom section B:		through 18-30VDC field power (feed to AO0 Vin+ terminal).		
Pin 1:	DI Common	,		
Pin 29:	DI0 – DI7	Output range:		0/4 to 20mA
Pin 10:	AO0 Vin +	Resolution:		16 bits
Pin 11:	AO0 I out	Accuracy (at 25°C):		±0.1%
Pin 12:	AO0 Vin -			10.170
		Max load impodance	<b>.</b> .	
ELECTRICAL		<ul> <li>Max load impedance:</li> <li>700 Ohm with internal supply (AO0 Vin+ = N.C.)</li> <li>1K Ohm with external supply (AO0 Vin+ &gt; 20V)</li> </ul>		
Power consumption (from ba	ckplane bus):			
- Current consumption (min*):	90mA @ 12V	Isolation (output to	digital):	At least 1KV
- Current consumption (max**	ʻ): 150mA @ 12V			
- Power consumption (min):	1.1W	Relay outputs:		
<ul> <li>Power consumption (max):</li> </ul>	1.8W		tching rela	y outputs, SPDT, are
		provided.	0	
* All relay outputs are de-activ	vated, and analog output			
channel is disabled.		Load voltage:		Max 125 VDC
** All relay outputs are activat	ed, and analog output			
channel is sourcing the maxim	um value.	Load current resistiv	e:	
		- 2A @ 30VDC		
		- 0.25A @ 125VD	c	
Analog inputs:		0.25/(@12570	C	
3 channels (differential analog	inputs), with 16-bits	Output delay:		5ms (typical)
resolution is provided. IO14A	channels can measure	Output isolation:		2KV (1 minute)
current, IO14B channels can m	easure voltage.			zkv (i minute)
Input ranges*:				
- Type A (current mode):	0/4-20mA, 0/3.5-20.5mA	Digital inputs:		
- Type B (voltage mode):	0/1-5V, 0/0.875-5.125V	8 bipolar optical isol	ated digita	I inputs for 1224VDC
Type D (Voltage mode).	0,10,0,0,0,0,0,0,0,0,0	are provided. Inputs	s are isolat	ed from each other and
* Fach charged and he couffer		electronics.		
* Each channel can be configu				
operate in one of the above ra	inges.	Inputs 05 will prov	ide softwa	re counters, with up to
				50% duty cycle. Inputs 6
Effective resolution:	16 bit			nardware counters, with
Update time:	30ms (for all 3 channels)	up to 5kHz counting	• •	
Accuracy (at 25°C):	±0.1%			
Temperature drift:	± 25ppm/°C	A user programmabl	e dehound	ce filter, in 1ms units, is
Power-freq. noise rejection:	50Hz			, to filter out noise or
Digital low-pass filter:	User selectable	mechanical relay bo		
to and to an a				
Input impedance:	250 Ohm 10 4%	DI input voltage:		
- Type A (current mode):	250 Ohm ±0.1%	Input 05	Activate	ed 10 - 30 VDC.
- Type B (voltage mode):	>1MΩ			ated Max 3 VDC.
Isolation:				
- Input to digital:	At least 1KV	Input 67	Activate	ed 5 - 30 VDC.
- Channel to channel:	At least 250V			ated Max 2 VDC.
			_ = = = = = = = = = = = = = = = = = = =	
Analog output		DI input current:		
Analog output:	h 16-hits resolution is	Input 05	typical 2	2.5 mA @ 12 V
1 channel of analog output wit		Input 05		5 mA @ 24 V
provided. The channel has a cu	arrent output and could		cypical c	

> Document no. 40421 106 IO14A & IO14B

provided. The channel has a current output and could be supplied internally (AOO Vin+ is left unconnected) or



### IO14A & IO14B Data Sheet

Input 67	typical 4 mA @ 12 V
Input 67	typical 8 mA @ 24 V
Input delay:	100 µs typical.
Counters (DI 6-7)	Up to 5kHz @10-30VDC

Isolation

2KV (1 minute)

### Absolute maximum ratings\*:

Analog input current (type A): ±30mA Analog input voltage (type B): ±40VDC Analog output power (Vin+): ±35VDC Digital Input voltage: ±40VDC

\* Note: Exceeding the absolute maximum values MAY CAUSE PERMANENT DAMAGE to the module


### **Over voltage category II (OV II):** 250VAC/VDC


### Separated/Safe Extra Low Voltage (SELV) limits:

VAC (RMS)	30V
VAC (Peak)	42.4V
VDC	60V

**Note:** The SELV limits relies on input supply and all connected voltages.

### MECHANICAL





Mounting	DIN 35
Width	24 mm
Height	111.5 mm
Depth	94.5 mm
Weight	102 grams

### **ENVIRONMENTAL CONDITIONS**

Ambient operating temperature range	-25°C to +75°C
Ambient operating temperature range	-40°C to +85°C
Marked degree of protection	IP20
Humidity	099.8%
Ventilation Restrictions	No
Pollution degree	2

### **STANDARDS**

#### EMC:

- **IEC 61000-6-2**: EMC Immunity standard for industrial environments
- IEC 61000-6-4: EMC Emission standard for industrial environments
- IEC 50121-4: Railway applications EMC -Emission and immunity of the signalling and telecommunications apparatus

#### Safety:

- **IEC 60950-1**: Safety requirements for Information technology equipment
- IEC 61010-1: Safety requirements for electrical equipment for measurement, control, and laboratory use

### **Environmental:**

- IEC 60068-2-1: Environmental testing Cold
- IEC 60068-2-2: Environmental testing Dry heat
- **IEC 60068-2-30**: Environmental testing Damp heat, cyclic (12 h + 12 h cycle)
- IEC 60068-2-78: Environmental testing Damp heat, steady state
- IEC 60068-2-6: Environmental testing Vibration (sinusoidal)
- IEC 60068-2-27: Environmental testing Shock



### MODULE LED STATUS

A dual color (red/yellow) LED is provided on the module to indicate the module status. Yellow indicates the module mode / state and red indicates module error or warnings (according to the table below):

Status	Yellow	Red
Normal operating	ON	OFF
Communication timeout	Blinking	OFF
Module is not configured /	Single	OFF
wrong configuration	flashing	
Module is configured but	Double	OFF
is in stopped mode (ready	flashing	
for being started)		
Module is in firmware	Quadruple	OFF
update mode	flashing	
Communication error	N/A	Blinking
Communication warning	N/A	Single
		flashing
Corrupted module info in	N/A	Flickering
EEPROM		
Hardware fatal error	OFF	ON
No module power	OFF	OFF

Each pattern / color will operate in 2 sec duty cycles. When the red LED is inactive (off), only the 2 sec yellow duty cycle will operate (yellow is always active). When the red LED is active, a switch between 2 sec yellow, and 2 sec red patterns will occur.

### SAFETY PRECAUTIONS

- Follow the national safety regulation (IEC 61010-1)
- Only skilled person is allowed to install and operate the modules.
- Disconnect the input supply while working with relay module.
- Modules can only be mounted in an end-use enclosure which provides protection against fire, electrical and mechanical hazards.
- If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

Document no. 40421 106 IO14A & IO14B